

Revised List as of 12:45 p.m. based on TMT input
Prioritized List of FCRPS Operations Which May Be Used
During a NW or SW System Reliability Event
Final 7/31/00

1. Regional plea for energy conservation
2. Voluntary load curtailment of industrial users
3. Rescheduling of unit outages
4. Increase Willamette Projects' generation
5. Purchase all available energy
6. Maximize Treaty/Non Treaty water releases
7. JDA – increase operating range to 265 ft. to 262.5 ft.
8. ψGCL – draft at 1.5 ft/day (or until restricted by JDA cutplane)
9. LWG – utilize full operating pool
10. ALF – operate at full power to elevation 2062 ft. mindful of ramp rates.
11. TDA – reduce spill to 30%
12. TDA – reduce spill to 20%
13. BON – reduce daytime spill to 50 kcfs
14. JDA – reduce daytime spill to zero (JDA is expected to be at zero 7/31-8/3)
15. MCN – operate outside 1% operating efficiency at 50% overload (approx. 72 Mws)
16. HGH – operate all available units (bring up to 3 units until further notice)
17. *JDA – reduce spill to zero (nighttime)
18. *TDA – reduce spill to zero
19. *IHR – reduce spill to zero
20. *BON – reduce spill to zero
21. BON – operate outside of 1% operating efficiency
22. MCN - operate outside 1% operating efficiency at 100% overload (approx. 81 Mws)
23. ψBanks Lake – operate PGs / sag on Banks Lake to elevation 1565 ft.
24. ♦ψGCL – increase to 2 ft/day draft
25. ♦Snake River Projects – go to zero nighttime flow (lower Snake projects may go above MOP)
26. ♦DWR – increase discharge to 21 kcfs
27. ♦LIB – operate all available units (maintain minimum flow of 7 kcfs at night)
28. ♦JDA – increase operating pool range to a low of 260 ft.
29. ♦MCN – pull fish screens

The above list has been coordinated with the TMT.

- ψ Due to a fire at GCL 2nd powerhouse on 7/28/00, GCL is currently being base loaded and is not in a position at this time to respond as shown on the list above. This also impacts the operation of Banks Lake.
- * Items 17-20 may be utilized for up to six hours at a time. Judi Johansen will coordinate with the General Strock if additional hours are required.
- ♦ Items 24–29 will required additional coordination between Judi Johansen and General Strock and Mr. McDonald before being implemented.